



Ref. Certif. No.

**SE-101471A1**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Connector

Name and address of the applicant

NEUTRIK AG  
Im alten Riet 143,  
9494 Schaan Liechtenstein

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

See page 2

Ratings and principal characteristics

250V AC, 20A, IP20

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

RRAC3I-G-000-0, RRAC3O-G-000-0

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 61984:2008

As shown in the Test Report Ref. No. which forms part of this Certificate

2027988STO-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature:

Leif Mattsson

Date: 02 February, 2021

**Factories**

NEUTRIK AG  
Im alten Riet 143,  
9494 Schaan, Liechtenstein

Ningbo Lequn Electronics Co., Ltd.  
Shiqi Street, Yingxian Road West, Fengjia Village, HaiShu Area  
315153 Ningbo, Zhejiang, China

**Additional information**

Fixed connectors for power applications.  
CBC and COC without interlock.  
Fixed connectors with tab terminals (4,8 x 0,5mm).  
Cable connectors with screw terminals. PTI: 175. Pollution degree 2,  
Overvoltage category II, number of conductors 3, conductor area 1,5 – 4,0mm<sup>2</sup>

Additional flammability information:

Type	Part	Material	Thickness	Flammability
Fixed connectors RRAC3*	Inserts / housing (blue or grey)	PA66	0,4 – 2,0 mm	V-0 UL 94

This certificate replaces CB certificate SE-101471 dated 18 June 2020 due to new article names:  
RRAC3I-G-000-0, RRAC3O-G-000-0

Date: 02 February, 2021

Signature:

